



4630 West Jennifer Avenue, Suite 101  
Fresno, California 93722-6415  
Tel: (559) 447-9075  
Fax: (559) 447-9074  
Email: [Info@TriCityEngineering.com](mailto:Info@TriCityEngineering.com)  
[www.TriCityEngineering.com](http://www.TriCityEngineering.com)

## **ADDENDUM NO. 02**

### **CITY OF COALINGA Ramsey Splash Park Project No. PW 25-001**

**Bid Date: 03/24/2024, 2:00 P.M.**

**3/20/2026  
Issued By:**

A handwritten signature in black ink that reads "Erika Lansburgh".

**Erika Lansburgh, Project Manager  
Tri City Engineering, Inc.**





## ADDENDUM NO. 02

Date: March 20, 2026  
Project: Ramsey Splash Park  
Project No.: PW 25-001 / #3101  
Owner: City of Coalinga

### NOTICE: TO ALL PRIME CONTRACTORS

This Addendum, which is issued for clarification and interpretation, forms a part of the Contract Documents and modifies any prior Addenda and the original Bidding Documents dated March 5, 2026 only to the extent stated herein. Submit this addendum, signed by the bidder, as a part of the Bid Form.

PLEASE ACKNOWLEDGE THIS ADDENDUM BY SIGNING BELOW AND FAXING OR EMAILING THIS SHEET, PAGE A2-1 ONLY, TO (559) 447-9074 OR INFO@TRICITYENGINEERING.COM.

Company Name: .....

By: .....

Date: .....

Acknowledge receipt of this Addendum in the space provided in the Proposal. Failure to do so may disqualify the Bidder.

#### **This Addendum consists of a total of forty-nine (49) pages, consisting of the following:**

1. Addendum No. 02, dated March 20, 2026. Total of 2 pages.
2. California Commercial Pools Plan Set – Not for construction. Total of 12 pages.
3. Green Flush Restrooms Plan Set – Not for construction. Total of 27 pages.
4. RCP Shelter Inc. Plan set. Total of 6 pages.
5. Green Flush Lift Plan. Total of 1 page.
6. Green Flush Pull Together Plan. Total of 1 page.

### **RESPONSE TO CONTRACTORS' QUESTIONS**

1. **Can you confirm whether the soil will remain in piles or if it will be spread out across the site?**
  - a) After speaking with the city and contractors, it seems the best approach is to leave the soil in piles, so the contractor can spread it out across the site as needed.
2. **What is the address of the location where the extra soil is located?**
  - a) Additional soil material has been brought to the site since the pre-bid meeting that was held on site. With this added material, there should be sufficient soil on-site to meet all fill requirements. If additional material is needed, the contractor will be required to haul it from 131 E. Cedar Ave, which is located near the project site.

- 3. Is the cost of the modular restroom by Green Flush is being covered?**
  - a) Yes, the cost of the modular restroom provided by Green Flush is covered and is not the responsibility of the prime contractor.
  
- 4. Will there be an addendum covering everything that is being required to be connected and installed inside the modular restroom?**
  - a) Lift and pull together plans have been provided by Green Flush—please refer to the attached documents. Installation instructions will be provided following the pre-construction meeting
  
- 5. Who will be held responsible for demoing and patching material that is ahead of schedule?**
  - a) During the pre-construction meeting, the schedule will be coordinated among all contractors. If delays occur, we will work with the contractors to confirm responsibility for any required patching.
  
- 6. Does the pre-fab modular restroom come with their personal electrical panels?**
  - a) Yes, the prefabricated modular unit includes two panels. However, the prime contractor is only responsible for the MDP, which includes connecting it to the vault and the internal panels. For additional information, please refer to sheet E-1.
  
- 7. Is there a plan set we could refer to for the columns in the shade structure?**
  - a) Yes, see the shade structure plan set attached. We are still awaiting final plans from vendors please see reference plans attached

**Attached files:**

- 1. California Commercial Pools Plan Set – Not for construction**
- 2. Green Flush Restrooms Plan Set – Not for construction**
- 3. RCP Shelter Inc. Plan set**
- 4. Green Flush Lift Plan**
- 5. Green Flush Pull Together Plan**

See box link for attachments: <https://tricityengineering.box.com/s/tr5oekmtreg488mtijd9td5fe8sx2rs0>